



PSB Singapore

CERTIFICATE OF CONFORMITY

Product Listing Scheme* : Class 1A

This Certificate is issued to

Keystone Cable (S) Pte Ltd
27 Senoko Way
Singapore 758060

FOR

Product: PVC insulated Non sheathed cable
Brand: KEYSTONE
Model: -
Country of Origin: Singapore
Product Details: Voltage: 450/750V, Insulation: PVC,
Sizes: 1C x 1.5mm² to 1C x 630mm²

which has complied with the requirements of the scheme and based on the following:

Standard(s)

SS 358 : Part 3 : 1996 + A1:1998

Test Report(s)

SM/K/32/02/99/02/A,
SM/K/32/02/00/02/A,
SM/K/32/02/01/02/A,
SM/K/32/02/02/01/B,
S09EEC01798/A/RON/THP,
S09EEC01798/RON/THP

Vice-President (Certification Department)
TÜV SÜD PSB

Certificate No:	Date of Original Issue:	Date of Last Revision:	Date of Expiry:
022361	18/06/2002	08/07/2011	17/06/2014



* All products listed under Class 1A/1B must have this mark affixed / printed on them. Failure to comply with this requirement may result in revocation of this certificate.

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the Product Listing Scheme. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at www.tuv-sud-psb.com.

Test Report No. 7191061602-EEC13
dated 27 Jun 2013



PSB Singapore

Note: This report is issued subject to the Testing and Certification Regulations of the TÜV SÜD Group and the General Terms and Conditions of Business of TÜV SÜD PSB Pte Ltd. In addition, this report is governed by the terms set out within this report.

Choose certainty.
Add value.

Subject

TESTING OF CABLES

Client

EPAN INDUSTRIES (PTE) LTD
19 Benoi Road
Singapore 629909

Attn: Ms. Cai Xiao Jie

Sample Submission Date

10 Jun 2013

Date(s) of Performance of Test

11 Jun 2013 to 26 Jun 2013

Description of Samples

Type	:	CU/PVC/PVC Cable
Brand	:	SIGMA WIRE
Size	:	1) 3C/40, 2) 3C/70, 3) 4C/40
Voltage	:	250 / 440 V
Conductor	:	Flexible plain copper wires (class 5)
Insulation	:	PVC 3C/40 & 3C/70 (Brown, Blue & Green / Yellow) 4C/40 (Brown, Blue, Black & Green / Yellow)
Outer sheath	:	PVC (Grey)
Manufacturer	:	Pacific Electric Wire & Cable
Country of origin	:	Taiwan



TÜV SÜD PSB

Laboratory:
TÜV SÜD PSB Pte. Ltd.
No.1 Science Park Drive
Singapore 118221

Phone : +65-6885 1333
Fax : +65-6776 8670
E-mail: testing@tuv-sud-psb.sg
www.tuv-sud-psb.sg
Co. Reg : 199002667R

Regional Head Office:
TÜV SÜD Asia Pacific Pte. Ltd.
3 Science Park Drive, #04-01/05
The Franklin, Singapore 118223
TUV®